



Superheat means the suction line is warmer than the evaporator

Subcooling means the liquid line is cooler than the condenser. (12 to 15° = NORMAL)