



Superheat means the suction line is warmer than the evaporator

Subcooling means the liquid line is cooler than the condenser (12° to 15° = NORMAL)